

Isobutane Pressure can**075_01**

Country : DE / Language : EN

- Response : P377 - Leaking gas fire: Do not extinguish, unless leak can be stopped safely..
P381 - In case of leakage, eliminate all ignition sources.
- Storage : P403 - Store in a well-ventilated place..

2.3. Other hazards

: Contact with liquid may cause cold burns/frostbite.

SECTION 3: Composition/information on ingredients**3.1. Substances**

Name	Product identifier	Composition [V-%]:	Classification according to Regulation (EC) No. 1272/2008 [CLP]
Isobutane	(CAS-No.) 75-28-5 (EC-No.) 200-857-2 (EC Index-No.) 601-004-00-0 (Registration-No.) 01-2119485395-27	100	Flam. Gas 1, H220 Press. Gas (Liq.), H280

*Contains no other components or impurities which will influence the classification of the product.***3.2. Mixtures** : Not applicable.**SECTION 4: First aid measures****4.1. Description of first aid measures**

- Inhalation : Remove victim to uncontaminated area wearing self contained breathing apparatus. Keep victim warm and rested. Call a doctor. Perform cardiopulmonary resuscitation if breathing stopped.
- Skin contact : In case of frostbite spray with water for at least 15 minutes. Apply a sterile dressing. Obtain medical assistance.
- Eye contact : Immediately flush eyes thoroughly with water for at least 15 minutes.
- Ingestion : Ingestion is not considered a potential route of exposure.

4.2. Most important symptoms and effects, both acute and delayed

: Refer to section 11.

4.3. Indication of any immediate medical attention and special treatment needed

: None.

SECTION 5: Firefighting measures**5.1. Extinguishing media**

- Suitable extinguishing media : Water spray or fog.
Dry powder.
- Unsuitable extinguishing media : Carbon dioxide.
Do not use water jet to extinguish.

5.2. Special hazards arising from the substance or mixture

- Specific hazards : Exposure to fire may cause containers to rupture/explode.
- Hazardous combustion products : Carbon monoxide.

Isobutane Pressure can**075_01**

Country : DE / Language : EN

5.3. Advice for firefighters

Specific methods

: Use fire control measures appropriate for the surrounding fire. Exposure to fire and heat radiation may cause gas receptacles to rupture. Cool endangered receptacles with water spray jet from a protected position. Prevent water used in emergency cases from entering sewers and drainage systems.

If possible, stop flow of product.

Use water spray or fog to knock down fire fumes if possible.

Do not extinguish a leaking gas flame unless absolutely necessary. Spontaneous/explosive re-ignition may occur. Extinguish any other fire.

Move containers away from the fire area if this can be done without risk.

Special protective equipment for fire fighters

: In confined space use self-contained breathing apparatus.

Standard protective clothing and equipment (Self Contained Breathing Apparatus) for fire fighters.

Standard EN 137 - Self-contained open-circuit compressed air breathing apparatus with full face mask.

Standard EN 469 - Protective clothing for firefighters. Standard - EN 659: Protective gloves for firefighters.

SECTION 6: Accidental release measures**6.1. Personal precautions, protective equipment and emergency procedures**

: Try to stop release.

Evacuate area.

Monitor concentration of released product.

Consider the risk of potentially explosive atmospheres.

Wear self-contained breathing apparatus when entering area unless atmosphere is proved to be safe.

Eliminate ignition sources.

Ensure adequate air ventilation.

Prevent from entering sewers, basements and workpits, or any place where its accumulation can be dangerous.

Act in accordance with local emergency plan.

Stay upwind.

6.2. Environmental precautions

: Try to stop release.

6.3. Methods and material for containment and cleaning up

: Keep area evacuated and free from ignition sources until any spilled liquid has evaporated (ground free from frost).

6.4. Reference to other sections

: See also sections 8 and 13.

SECTION 7: Handling and storage**7.1. Precautions for safe handling**

Safe use of the product

: The product must be handled in accordance with good industrial hygiene and safety procedures.

Only experienced and properly instructed persons should handle gases under pressure.

Consider pressure relief device(s) in gas installations.

Ensure the complete gas system was (or is regularly) checked for leaks before use.

Do not smoke while handling product.

Use only properly specified equipment which is suitable for this product, its supply pressure and temperature. Contact your gas supplier if in doubt.

Avoid suck back of water, acid and alkalis.

Assess the risk of potentially explosive atmospheres and the need for explosion-proof equipment.

Purge air from system before introducing gas.

Isobutane Pressure can

075_01

Country : DE / Language : EN

Take precautionary measures against static discharge.
 Keep away from ignition sources (including static discharges).
 Consider the use of only non-sparking tools.
 Do not breathe gas.
 Avoid release of product into atmosphere.
 Ensure equipment is adequately earthed.

Safe handling of the gas receptacle

: Refer to supplier's container handling instructions.
 Do not allow backfeed into the container.
 Protect cylinders from physical damage; do not drag, roll, slide or drop.
 When moving cylinders, even for short distances, use a cart (trolley, hand truck, etc.) designed to transport cylinders.
 Leave valve protection caps in place until the container has been secured against either a wall or bench or placed in a container stand and is ready for use.
 If user experiences any difficulty operating cylinder valve discontinue use and contact supplier.
 Never attempt to repair or modify container valves or safety relief devices.
 Damaged valves should be reported immediately to the supplier.
 Keep container valve outlets clean and free from contaminants particularly oil and water.
 Replace valve outlet caps or plugs and container caps where supplied as soon as container is disconnected from equipment.
 Close container valve after each use and when empty, even if still connected to equipment.
 Never attempt to transfer gases from one cylinder/container to another.
 Never use direct flame or electrical heating devices to raise the pressure of a container.
 Do not remove or deface labels provided by the supplier for the identification of the cylinder contents.
 Suck back of water into the container must be prevented.
 Open valve slowly to avoid pressure shock.

7.2. Conditions for safe storage, including any incompatibilities

: Observe all regulations and local requirements regarding storage of containers.
 Containers should not be stored in conditions likely to encourage corrosion.
 Container valve guards or caps should be in place.
 Containers should be stored in the vertical position and properly secured to prevent them from falling over.
 Stored containers should be periodically checked for general condition and leakage.
 Keep container below 50°C in a well ventilated place.
 Store containers in location free from fire risk and away from sources of heat and ignition.
 Keep away from combustible materials.
 Segregate from oxidant gases and other oxidants in store.
 All electrical equipment in the storage areas should be compatible with the risk of a potentially explosive atmosphere.

7.3. Specific end use(s)

: None.

SECTION 8: Exposure controls/personal protection

8.1. Control parameters

Isobutane Pressure can (75-28-5)		
OEL : Occupational Exposure Limits		
Germany	TWA (DE) OEL 8h [mg/m ³] TRGS 900	2400 mg/m ³
	TWA (DE) OEL 8h [ppm] TRGS 900	1000 ppm
	Peak exposure limitation factor (DE) OEL TRGS 900	4(II)
	Remark (TRGS 900)	DFG

DNEL (Derived-No Effect Level) : No data available.

PNEC (Predicted No-Effect Concentration) : No data available.

Isobutane Pressure can**075_01**

Country : DE / Language : EN

8.2. Exposure controls**8.2.1. Appropriate engineering controls**

- : Provide adequate general and local exhaust ventilation.
- Product to be handled in a closed system.
- Systems under pressure should be regularly checked for leakages.
- Ensure exposure is below occupational exposure limits (where available).
- Gas detectors should be used when flammable gases/vapours may be released.
- Consider the use of a work permit system e.g. for maintenance activities.

8.2.2. Individual protection measures, e.g. personal protective equipment

- : A risk assessment should be conducted and documented in each work area to assess the risks related to the use of the product and to select the PPE that matches the relevant risk. The following recommendations should be considered:
 - PPE compliant to the recommended EN/ISO standards should be selected.
- Eye/face protection
 - : Wear goggles when transfilling or breaking transfer connections.
 - Standard EN 166 - Personal eye-protection - specifications.
- Skin protection
 - Hand protection
 - : Wear working gloves when handling gas containers.
 - Standard EN 388 - Protective gloves against mechanical risk.
 - Wear cold insulating gloves when transfilling or breaking transfer connections.
 - Standard EN 511 - Cold insulating gloves.
 - Other
 - : Consider the use of flame resistant anti-static safety clothing.
 - Standard EN ISO 14116 - Limited flame spread materials.
 - Standard EN 1149-5 - Protective clothing: Electrostatic properties.
 - Wear safety shoes while handling containers.
 - Standard EN ISO 20345 - Personal protective equipment - Safety footwear.
- Respiratory protection
 - : Gas filters may be used if all surrounding conditions e.g. type and concentration of the contaminant(s) and duration of use are known.
 - Use gas filters with full face mask, where exposure limits may be exceeded for a short-term period, e.g. connecting or disconnecting containers.
 - Recommended: Filter AX (brown).
 - Gas filters do not protect against oxygen deficiency.
 - Standard EN 14387 - Gas filter(s), combined filter(s) and standard EN136, full face masks .
- Thermal hazards
 - : None in addition to the above sections.

8.2.3. Environmental exposure controls

- : Refer to local regulations for restriction of emissions to the atmosphere. See section 13 for specific methods for waste gas treatment.

SECTION 9: Physical and chemical properties**9.1. Information on basic physical and chemical properties**

Appearance

- Physical state at 20°C / 101.3kPa : Gas.
 - Colour : Colourless.
- Odour : Stenchant often added. Sweetish. Poor warning properties at low concentrations.
- Odour threshold : Odour threshold is subjective and inadequate to warn of overexposure.
- Melting point : -159 °C
- Boiling point : -12 °C
- Flash point : Not applicable for gases and gas mixtures.
- Flammability range : 1.5 - 9.4 vol %
- Relative vapour density at 20 °C : Not applicable.
- Evaporation rate (ether=1) : Not applicable for gases and gas mixtures.
- Vapour pressure [20°C] : 3 bar(a)

Isobutane Pressure can**075_01**

Country : DE / Language : EN

Vapour pressure [50°C]	: 6.9 bar(a)
Relative density, gas (air=1)	: 2
Relative density, liquid (water=1)	: 0.59
Solubility in water	: 54 mg/l
pH value	: Not applicable for gases and gas mixtures.
Partition coefficient n-octanol/water [log Kow]	: 2.76
Decomposition point [°C]	: Not applicable.
Auto-ignition temperature	: 460 °C
Viscosity [20°C]	: No reliable data available.
Explosive Properties	: Not applicable.
Oxidising Properties	: Not applicable.

9.2. Other information

Molar mass	: 58 g/mol
Critical temperature [°C]	: 135 °C
Other data	: Gas/vapour heavier than air. May accumulate in confined spaces, particularly at or below ground level.

SECTION 10: Stability and reactivity**10.1. Reactivity**

: No reactivity hazard other than the effects described in sub-sections below.

10.2. Chemical stability

: Stable under normal conditions.

10.3. Possibility of hazardous reactions: Can form explosive mixture with air.
May react violently with oxidants.**10.4. Conditions to avoid**: Keep away from heat/sparks/open flames/hot surfaces. – No smoking.
Avoid moisture in installation systems.**10.5. Incompatible materials**: Air, Oxidisers.
For additional information on compatibility refer to ISO 11114.**10.6. Hazardous decomposition products**

: Under normal conditions of storage and use, hazardous decomposition products should not be produced.

SECTION 11: Toxicological information**11.1. Information on toxicological effects**

Acute toxicity	: Toxicological effects not expected from this product if occupational exposure limit values are not exceeded.
Skin corrosion/irritation	: No known effects from this product.
Serious eye damage/irritation	: No known effects from this product.
Respiratory or skin sensitisation	: No known effects from this product.
Germ cell mutagenicity	: No known effects from this product.
Carcinogenicity	: No known effects from this product.
Reproductive toxicity	:
Toxic for reproduction : Fertility	: No known effects from this product.
Toxic for reproduction : unborn child	: No known effects from this product.
STOT-single exposure	: No known effects from this product.
STOT-repeated exposure	: No known effects from this product.

Isobutane Pressure can**075_01**

Country : DE / Language : EN

Aspiration hazard : Not applicable for gases and gas mixtures.**SECTION 12: Ecological information****12.1. Toxicity**

Assessment : Classification criteria are not met.

EC50 48h - Daphnia magna [mg/l] : 16.3 mg/l

EC50 72h - Algae [mg/l] : 8.6 mg/l

LC50 96 h - fish [mg/l] : 28 mg/l

12.2. Persistence and degradability

Assessment : The substance is readily biodegradable. Unlikely to persist.

12.3. Bioaccumulative potentialAssessment : Not expected to bioaccumulate due to the low log Kow (log Kow < 4).
Refer to section 9.**12.4. Mobility in soil**Assessment : Because of its high volatility, the product is unlikely to cause ground or water pollution.
Partition into soil is unlikely.**12.5. Results of PBT and vPvB assessment**

Assessment : Not classified as PBT or vPvB.

12.6. Other adverse effects

Other adverse effects : No known effects from this product.

Effect on the ozone layer : None.

Global warming potential [CO₂=1] : 3Effect on global warming : Contains greenhouse gas(es).
When discharged in large quantities may contribute to the greenhouse effect.**SECTION 13: Disposal considerations****13.1. Waste treatment methods**

Contact supplier if guidance is required.

Do not discharge into areas where there is a risk of forming an explosive mixture with air.

Waste gas should be flared through a suitable burner with flash back arrestor.

Do not discharge into any place where its accumulation could be dangerous.

Ensure that the emission levels from local regulations or operating permits are not exceeded.

Refer to the EIGA code of practice Doc.30 "Disposal of Gases", downloadable at

<http://www.eiga.org> for more guidance on suitable disposal methods.

Return unused product in original cylinder to supplier.

List of hazardous waste codes (from Commission Decision 2001/118/EC) : 16 05 04 *: Gases in pressure containers (including halons) containing hazardous substances.

13.2. Additional information

: External treatment and disposal of waste should comply with applicable local and/or national regulations.

SECTION 14: Transport information**14.1. UN number**

Isobutane Pressure can**075_01**

Country : DE / Language : EN

UN-No. : 2037

14.2. UN proper shipping name**Transport by road/rail (ADR/RID)** : RECEPTACLES, SMALL, CONTAINING GAS (GAS CARTRIDGES)**Transport by air (ICAO-TI / IATA-DGR)** : Receptacles, small, containing gas**Transport by sea (IMDG)** : RECEPTACLES, SMALL, CONTAINING GAS (GAS CARTRIDGES)**14.3. Transport hazard class(es)****Labelling** :

2.1 : Flammable gases.

Transport by road/rail (ADR/RID)

Class : 2.

Classification code : 5F.

Tunnel Restriction : D - Passage forbidden through tunnels of category D and E.

Transport by air (ICAO-TI / IATA-DGR)

Class / Div. (Sub. risk(s)) : 2.1

Transport by sea (IMDG)

Class / Div. (Sub. risk(s)) : 2.1

Emergency Schedule (EmS) - Fire : F-D.

Emergency Schedule (EmS) - Spillage : S-U.

14.4. Packing group

Transport by road/rail (ADR/RID) : Not established.

Transport by air (ICAO-TI / IATA-DGR) : Not established.

Transport by sea (IMDG) : Not established.

14.5. Environmental hazards

Transport by road/rail (ADR/RID) : None.

Transport by air (ICAO-TI / IATA-DGR) : None.

Transport by sea (IMDG) : None.

14.6. Special precautions for user**Packing Instruction(s)**

Transport by road/rail (ADR/RID) : P003.

Transport by air (ICAO-TI / IATA-DGR)

Passenger and Cargo Aircraft : 203.

Cargo Aircraft only : 203.

Transport by sea (IMDG) : P003.

Special transport precautions

: Avoid transport on vehicles where the load space is not separated from the driver's compartment.

Ensure vehicle driver is aware of the potential hazards of the load and knows what to do in the event of an accident or an emergency.

Before transporting product containers:

- Ensure there is adequate ventilation.
- Ensure that containers are firmly secured.
- Ensure cylinder valve is closed and not leaking.
- Ensure valve outlet cap nut or plug (where provided) is correctly fitted.
- Ensure valve protection device (where provided) is correctly fitted.

Isobutane Pressure can**075_01**

Country : DE / Language : EN

14.7. Transport in bulk according to Annex II of Marpol and the IBC Code

: Not applicable.

SECTION 15: Regulatory information**15.1. Safety, health and environmental regulations/legislation specific for the substance or mixture****EU-Regulations**

Restrictions on use : None.
Seveso Directive : 2012/18/EU (Seveso III) : Listed.

National regulations

National legislation : Ensure all national/local regulations are observed.

Germany

Water hazard class (WGK) : Water hazard class (WGK) nwg, Non-hazardous to water (Classification according to VwVwS, Annex 1 or 2; ID No. 562)

Other information, restrictions and prohibition regulations : [German regulations] BetriebssicherheitsV mit TRBSen insbesondere TRBS 3145 / TRGS 725 Ortsbewegliche Druckgasbehälter", TRBS 2141, BGR Regel 500 Teil 2.33: "Umgang mit Gasen", GefahrstoffV mit Technischen Regeln Gefährliche Stoffe TRGS insbesondere TRGS 407 "Tätigkeiten mit Gasen - Gefährdungsbeurteilung", TRGS 400, 500, 510, 900." BGR 104, TRBS 2152.

15.2. Chemical safety assessment

A CSA has been carried out.

SECTION 16: Other information

Indication of changes : Revised safety data sheet in accordance with commission regulation (EU) No 453/2010.

Abbreviations and acronyms : ATE - Acute Toxicity Estimate
CLP - Classification Labelling Packaging Regulation; Regulation (EC) No 1272/2008
REACH - Registration, Evaluation, Authorisation and Restriction of Chemicals Regulation (EC) No 1907/2006
EINECS - European Inventory of Existing Commercial Chemical Substances
CAS# - Chemical Abstract Service number
PPE - Personal Protection Equipment
LC50 - Lethal Concentration to 50 % of a test population
RMM - Risk Management Measures
PBT - Persistent, Bioaccumulative and Toxic
vPvB - Very Persistent and Very Bioaccumulative
STOT- SE : Specific Target Organ Toxicity - Single Exposure
CSA - Chemical Safety Assessment
EN - European Standard
UN - United Nations
ADR - European Agreement concerning the International Carriage of Dangerous Goods by Road
IATA - International Air Transport Association
IMDG code - International Maritime Dangerous Goods
RID - Regulations concerning the International Carriage of Dangerous Goods by Rail
WGK - Water Hazard Class

Training advice : Ensure operators understand the flammability hazard.

Further information : This Safety Data Sheet has been established in accordance with the applicable European Union legislation.

Full text of H- and EUH-statements

Flam. Gas 1

Flammable gases, Category 1

Isobutane Pressure can**075_01**

Country : DE / Language : EN

Press. Gas (Liq.)	Gases under pressure : Liquefied gas
H220	Extremely flammable gas.
H280	Contains gas under pressure; may explode if heated.

DISCLAIMER OF LIABILITY

: Before using this product in any new process or experiment, a thorough material compatibility and safety study should be carried out.

Details given in this document are believed to be correct at the time of going to press.

Whilst proper care has been taken in the preparation of this document, no liability for injury or damage resulting from its use can be accepted.